

CHARTER TOWNSHIP OF FENTON

12060 Mantawauka Drive

Fenton, Michigan 48430

Phone (810) 629-1537 Fax (810) 629-9736

—

SEWER CONTRACTOR PERMIT APPLICATION

Date of application: ____/____/____ ____ New Application ____ Renewal

Contractor Name: _____

Address: _____

City/State/Zip: _____

Telephone Number: _____

Please include the following with your permit application:

Certificate of Workers Compensation Insurance

Certificate of Liability Insurance - minimum \$100,000 personal injury/\$300,000 aggregate

- minimum \$100,000 property damage

Workmanship Surety Bond - \$10,000

\$30 check payable to the Charter Township of Fenton

Applicant Signature: _____

[See reverse side for sewer construction regulations]

CHARTER TOWNSHIP OF FENTON

Service Lead Construction Specifications

No sewer connection shall be directly connected to any County or Township sewer by any person without first obtaining a permit from the Charter Township of Fenton. Contractors shall be licensed and bonded with the Charter Township of Fenton before a permit will be issued.

1. The Contractor shall inspect the service lead/riser for any defects (i.e.: backfill, cracked pipe, obstructions, etc.). The Contractor shall repair any deficiencies found.
2. The service lead shall be 4" schedule 40 PVC for single family/multi family. Commercial facilities shall be 6" schedule 40 PVC.
3. The Contractor shall connect to the 6" riser in the following manner: Use a 6" to 4" Fernco coupling for single family/multi family. Make sure pipes are firmly connected and properly bedded after installation. (If commercial use a 6" to 6" Fernco coupling).
4. PVC purple primer and PVC bonding cement shall be used on service leads.
5. A fall of 1 ¼ inch per 10 feet shall be maintained.
6. The service lead shall have a minimum of 18" of cover over top of pipe.
7. All service leads constructed under a surface with vehicular traffic shall be sleeved according to Genesee County Standard Specification.
8. Service leads shall have a clean – out installed within 5' of building and a clean – out every 90' thereafter.
9. The clean–out shall be installed using a "Y" and 45° bend fitting.
10. 90° turns shall not be installed.
11. All connections to existing building pipes shall be made using Fernco fittings.
12. When disconnecting septic and connecting to sanitary sewer, the septic tank shall be pumped and filled with sand.
13. When two (2) leads are hooked to one (1) tap, 6" schedule 40 shall be installed to the building.
14. Basement walls, floor and covered roof shall be complete before service lead can be brought to building.
15. In some cases HDPE pipe may be used. The Township Supervisor shall approve or deny the use of HDPE.